



This document confirms that Lomax+Wood has had its standard products acoustic rating tested to BS EN ISO 10140 at Exova BMTRADA, a UKAS accredited certification body. The following table includes the product type, glass specification and the ratings achieved:

<i>Product Name</i>	<i>Glazing Specification</i>	<i>Certificate No.</i>	<i>Test Result R<sub>w</sub> (C;C<sub>tr</sub>)</i>
Spring Sash Windows	4mm Tgh / 16mm Argon / 4mm Tgh Low E	BMT/MTP/F15193/02	36 (-1;-3) dB
Spring Sash Windows	6.4mm PVB Silence Lam / 16mm Argon / 4mm Tgh Low E	BMT/MTP/F15193/02	38 (-1;-3) dB
Box Sash Windows	4mm Tgh / 16mm Argon / 4mm Tgh Low E	BMT/MTP/F15193/03	36 (-1;-3) dB
Box Sash Windows	6.4mm PVB Silence Lam / 16mm Argon / 4mm Tgh Low E	BMT/MTP/F15193/03	38 (-2;-2) dB
Casement Windows	4mm Tgh / 16mm Argon / 4mm Tgh Low E	BMT/MTP/F15193/01	38 (-1;-4) dB
Casement Windows	6.4mm PVB Silence Lam / 16mm Argon / 4mm Tgh Low E	BMT/MTP/F15193/01	42 (-1;-5) dB